

**Carter Lake Filter Plant
2022 CCR Data**

Miscellaneous Compounds Summary

Test Name	Water Tested	High Result (mg/L)	Low Result (mg/L)	Average Result (mg/L)	Testing Frequency
Alkalinity	Raw	28.00	21.00	24.70	Monthly
	Finished	40.00	19.00	31.80	Monthly
Calcium Hardness	Raw	26.40	20.90	23.30	Monthly
	Finished	51.10	18.70	27.00	Monthly
Total Hardness	Raw	28.70	24.90	26.50	Monthly
	Finished	67.70	25.70	32.00	Monthly
Dissolved Oxygen	Raw	10.90	7.70	9.40	Monthly
	Finished	10.60	8.10	9.50	Monthly
True Color	Raw	14.00	4.00	7.60	Monthly
	Finished	1.00	0.00	0.30	Monthly
Manganese	Raw	0.021	0.007	0.013	Monthly
	Finished	0.028	0.001	0.006	Monthly
Iron	Raw	0.050	0.001	0.031	Monthly
	Finished	0.050	0.020	0.024	Monthly
Fluoride	Raw	0.37	0.02	0.24	Monthly
	Finished	0.96	0.31	0.68	Daily
Conductivity	Raw	45.0	21.0	36.9	Monthly
	Finished	106.0	28.0	55.0	Monthly
Nitrate	Raw	0.10	0.00	0.00	Monthly
Chlorine Demand	Raw	0.84	0.54	0.68	Monthly
Chlorine Dioxide	Finished	0.27	0.00	0.01	Daily
Chlorite	Finished	0.57	0.08	0.35	Daily